

Sizing Of Reactive Power Compensators For Onshore And Offshore Grid Connected Wind Farms

Mohamad Abd-Alraheim Badr ,Ahmad,M., Elshimy,M

Abstract

The analysis of reactive demands of high voltage transmission links connecting wind farms to the central grid is considered in this paper. Both High Voltage AC (HVAC) and High Voltage DC (HVDC) options as well as overhead and cable transmission alternatives are considered in the analysis. Therefore, the presented work is applicable for both onshore and offshore installations considering various transmission technologies. The sizing of the required reactive power compensators for the transmission system is the main objective of the manuscript. The target is to keep acceptable operating voltage limits through appropriate amounts of reactive power injection or absorption at the wind farms interface bus. The considered wind farm is made up with DFIGs. Based on the reactive power capability limits of the DFIGs comprising the wind farm, the minimum rating, and type of external reactive power compensating devices are determined for various transmission options. In addition, the reactive power loading on the compensators at various operating conditions of the wind farm is determined.

Industry Academia Collaboration (IAC) Conference, Energy And Sustainable Development Track, Apr. 6 6":."4237."Cairo, Egypt. 2015, April